



CHINO VALLEY INDEPENDENT FIRE DISTRICT FIRE PROTECTION STANDARD

PRE-FIRE PLAN

STANDARD # 143

REVISED 07/07/1992 PAGES 2
























PURPOSE: The purpose of this standard is to provide an accurate and comprehensive site plan for the fire department. The pre-fire plan will be used by emergency response personnel for use in the field.

SCOPE: This standard covers the required items that shall be shown on the site plan by the use of standard recognized symbols.

PROCEDURE:

1. A site plan shall be submitted in a CAD drawing in DWG format.
2. The site plan shall include access areas, adjacent streets, building footprints, fire hydrant locations, utility shut-off locations, fire sprinkler riser locations, control valves (P.I.V.), fire department connection (F.D.C.), fire alarm panel locations, fire sprinklers, inspector's test valve, standpipes, hose cabinets, stairways, Knox key locations, railroad tracks, fences, hazardous materials, other special hazards and any other important information.
3. The standard symbols shown on the attached sheet shall be utilized.

**CHINO VALLEY FIRE DEPARTMENT
STANDARD SYMBOLS
FOR PRE-PLANS**

AUTOMATIC SPRINKLERS		FIRE ALARM BELL OR ANNUNCIATOR PANEL	
NON-SPRINKLERED		GAS SHUT OFF	
SPRINKLER RISER		WATER SHUT OFF	
RACK SPRINKLER RISER		ELECTRICITY SHUT OFF	
WET STAND PIPE		IMPORTANT INFORMATION/ NOTES	
HOSE CABINET		DANGER WARNING, SPECIAL HAZARDS	
FIRE DEPARTMENT CONNECTION		RAILROAD TRACKS	
POST INDICATOR VALVE		KNOX BOX LOCATION	
INSPECTORS TEST VALVE		KNOX SWITCH LOCATION	
FIRE HYDRANT (STEAMER)		KNOX VAULT LOCATION	
FIRE HYDRANT (WARF)		TURF BLOCKS/ TURF PAVERS/ RITTER RINGS	
FIRE HYDRANT (UNDERGROUND)			ACCESS